

Annexure-C

Appendix-XIII

PEROFORMA FOR SAFE DIRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.: 614

Date: 06/08/2026

It is certified that an inspection team headed by Rameshwar Prasad, Assistant Engineer From Public Health Sub-division, Ujiyarpur inspected the **INNOVATIVE VISION SCHOOL, EKDWARI (NORTH OF BAHERA CHOWK); PO-HANSA, DIST-SAMASTIPUR** on 05.08.2026 and found that the **INNOVATIVE VISION SCHOOL** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T Govt.


06/08/26


Signature with Seal.....

Name :- **Rameshwar Prasad**


Designation : **Sub-Divisional Officer**
P.H. Sub-Division, Ujiyarpur

TO,

**PRINCIPAL,
INNOVATIVE VISION SCHOOL,
EKDWARI (NORTH OF BAHERA CHOWK);
PO-HANSA, DIST-SAMASTIPUR**


Principal

**INNOVATIVE VISION SCHOOL
Ekdwari, Hansa,
Samastipur-84101**


5/8/2026

**Manager
INNOVATIVE VISION SCHOOL
Ekdwari, Hansa,
Samastipur-84101**

Government of Bihar
Public Health Engineering Department

DISTRICT :- SAMASTIPUR				DIVISION :- SAMASTIPUR														MONTH:-AUGUST 2026										REMARKS
S.N.	BLOCK	PANCHAYAT	LOCATION OF SOURCE	PARAMETERS																								
				pH	TURB	EC	TDS	TH	Ca	Cl	Mg	Alk.	Fe	T.CO.U														
1	WARIS NAGAR	HANSA (EKDWARI)	INNOVATIVE VISION SCHOOL (RO WATER)	7.1	1	345	224	108	24	28	13	120	0.2	-ve														
2	WARIS NAGAR	HANSA (EKDWARI)	INNOVATIVE VISION SCHOOL	7.5	2	686	446	205	36	44	19	196	0.5	-ve														
Acceptable Limit as per BIS 10500/2012				6.5-8.5	1 NTU	-	500 mg/l	200 mg/l	75 mg/l	2500 g/l	30 mg/l	200 mg/l	1.0mg/l															
Permissible Limit* in Absence of Alternate source as per BIS 10500/2012				NR	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	1000 mg/l	100 mg/l	600 mg/l	NR															

[Signature]
Principal
INNOVATIVE VISION SCHOOL
Ekdwar, Hansa,
Samastipur-848101

[Signature]
Manager
INNOVATIVE VISION SCHOOL
Ekdwar, Hansa,
Samastipur-848101

